

Fridge Temperature Log of VGHTC Clinical Trial Pharmacy

(Normal Range: 2 ~ 8°C)

PHCL-C003 (Model: R-1500)

Thermograph: ESCORT,1116-0018

Date (dd-mmm-yy)	Current (AM)			Current (PM)			Max. & Min.			Comments
	Time (hh:mm)	Temp (°C)	Signature (Initials)	Time (hh:mm)	Temp (°C)	Signature (Initials)	Max.Temp (°C)	Min.Temp (°C)	Signature (Initials)	
01-Nov-17	09:35	4.7	NTN	17:40	4.8	NTN	5.3	4.1	NTN	
02-Nov-17	08:58	5.3	NTN	17:15	5.2	STW	6.7	4.7	NTN	
03-Nov-17	08:10	4.7	NTN	17:45	5.3	NTN	5.7	4.6	NTN	
06-Nov-17	08:10	4.9	NTN	17:00	5.1	STW	5.8	4.7	NTN	
07-Nov-17	09:01	5.1	STW	17:05	5.6	STW	6.2	4.9	NTN	
08-Nov-17	08:15	5.4	YCS	18:07	5.3	NTN	5.8	5.0	NTN	
09-Nov-17	08:05	5.6	YCS	17:15	5.3	YCS	5.7	4.8	NTN	
10-Nov-17	08:05	5.2	YCS	17:05	5.1	STW	5.9	4.6	NTN	
13-Nov-17	08:34	5.2	NTN	17:00	5.1	STW	5.7	4.6	NTN	
14-Nov-17	09:30	5.3	STW	17:08	4.6	STW	5.7	4.2	NTN	
15-Nov-17	08:23	4.6	NTN	17:52	4.6	NTN	5.1	4.2	NTN	
16-Nov-17	09:15	4.7	NTN	16:57	5.1	STW	5.2	4.3	NTN	
17-Nov-17	09:10	4.5	NTN	17:05	4.7	STW	5.1	4.3	NTN	
20-Nov-17	08:15	4.4	NTN	17:40	4.8	STW	5.4	4.3	NTN	
21-Nov-17	08:15	5.2	NTN	17:00	5.1	STW	5.4	4.4	NTN	
22-Nov-17	08:00	4.7	NTN	17:30	4.6	NTN	5.4	4.6	NTN	
23-Nov-17	08:03	5.2	NTN	17:08	5.1	STW	5.7	4.6	NTN	
24-Nov-17	08:19	4.8	NTN	18:43	5.2	NTN	5.6	4.7	NTN	
27-Nov-17	08:08	5.6	NTN	17:00	4.9	YCS	5.6	4.9	NTN	
28-Nov-17	09:13	4.9	NTN	17:25	5.3	STW	5.9	4.9	NTN	
29-Nov-17	08:20	5.6	NTN	17:20	4.9	STW	5.8	4.5	NTN	
30-Nov-17	09:25	5.1	NTN	17:50	5.4	NTN	5.7	4.9	NTN	

Na = NTN 04 Dec 2017