


TCVGH Room Temperature Log

Air Temp (°C)



2026/4/1 下午 01:30:00	2026/4/11 下午 01:30:00	2026/4/21 下午 01:30:00	2026/5/1 下午 01:30:00	2026/5/11 下午 01:30:00	2026/5/21 下午 01:30:00	2026/5/31 下午 01:30:00
Sensor Name		Air Temp				
Legend						
Description		Room Temperature 3				
Serial Number		2106-0085				
Product Code		EI-HS-D-32-L				
Start		2026/4/1 下午 01:30:00				
Finish		2026/6/1 下午 02:10:00				
Sensor Range		-40.5 to 70.4 °C				
Specification		15.0 to 25.0 °C				
Average		21.8 °C				
Highest		23.4 °C				
Lowest		20.2 °C				

Yuan Su
6/20/2026