

# Room Temperature Log of VGHTC Clinical Trial Pharmacy

( Normal Range: 15°C ~ 25°C )

Model: ESCORT(1333-0016)

Date (dd-mmm-yy)	Time (hh:mm)	Current Temp(°C)	Current Humidity(%)	Maximum Temp(°C)	Minimum Temp(°C)	Comments	Signature (Initials)
04-Jan-16	08:10	20.4	72.6	20.8	20.3 <del>20.4</del>	NH 01 Feb 2016	NH
05-Jan-16	09:25	20.4	67.6	21.1	20.4		NH
06-Jan-16	09:00	21.0	71.8	21.1	20.7		NH
07-Jan-16	09:50	20.3	69.1	20.8	20.3		NH
08-Jan-16	08:30	20.4	69.8	20.5	20.3		NH
11-Jan-16	10:00	19.9	69.8	20.2	19.7		NH
12-Jan-16	09:05	18.6	67.0	19.6	18.5		NH
13-Jan-16	08:00	18.0	67.0	19.1	18.0		NH
14-Jan-16	09:40	19.2	66.9	19.4	19.1		NH
15-Jan-16	09:15	19.5	66.4	19.6	19.4		NH
18-Jan-16	09:00	19.5	60.3	19.7	19.3		NH
19-Jan-16	09:05	19.6	60.5	19.9	19.3		NH
20-Jan-16	08:45	19.4	59.8	19.8	18.9		NH
21-Jan-16	08:55	19.3	62.5	19.8	18.6		NH
22-Jan-16	09:35	18.8	60.4	19.8	18.8		NH
25-Jan-16	08:00	14.7	51.3	19.1	14.7	low temperature alarm	NH
26-Jan-16	09:15	18.4	42.7	20.2	18.0		NH
27-Jan-16	09:10	20.4	57.1	21.2	19.9		NH
28-Jan-16	09:30	20.9	67.0	21.5	20.6		NH
29-Jan-16	09:25	21.6	61.7	22.0	21.2		NH

Low temperature excursion occurred on 25 Jan 2016 (AM 5:00 ~ AM 8:00) due to strong cold fronts. Lowest temperature were 14.7°C. NH 25 Jan 2016

Nair-Hy 01 Feb 2016