


TCVGH Room temperature log



2019/2/25 下午 12:20:00 2019/3/2 下午 12:20:00 2019/3/7 下午 12:20:00 2019/3/12 下午 12:20:00 2019/3/17 下午 12:20:00 2019/3/22 下午 12:20:00 2019/3/27 下午 12:20:00

Sensor Name	Air Temp
Legend	
Description	Room temperature
Serial Number	1333-0016
Product Code	EI-HS-D-32-L
Start	2019/2/25 下午 12:20:00
Finish	2019/4/1 上午 08:50:00
Specification	15.0 to 25.0 °C
Average	19.7 °C
Highest	21.5 °C
Lowest	19.0 °C

Yunwen Wang
01 Apr 2019