


TCVGH Room Temperature Log

Air Temp (°C)



2019/8/30 下午 04:05:00	2019/9/4 下午 04:05:00	2019/9/9 下午 04:05:00	2019/9/14 下午 04:05:00	2019/9/19 下午 04:05:00	2019/9/24 下午 04:05:00	2019/9/29 下午 04:05:00
Sensor Name	Air Temp					
Legend						
Description	Room temperature					
Serial Number	1333-0016					
Product Code	EI-HS-D-32-L					
Start	2019/8/30 下午 04:05:00					
Finish	2019/10/1 上午 09:05:00					
Sensor Range	-40.5 to 70.4 °C					
Specification	15.0 to 25.0 °C					
Average	20.8 °C					
Highest	23.0 °C					
Lowest	19.6 °C					

Na-ZM
01 Oct 2019